



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-152-16**

Valid from: 2023 03 15
until: 2024 05 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Socket outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3722-1860/23**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2023 03 15



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
EN IEC 60309-1:2022
EN IEC 60309-2:2022
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Socket outlets for industrial purposes

Type designation:

Rating:

133

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

134

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

Trademark:

PCE / ELCEE / SIROX / METECEE

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

135

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1335

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1336

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1345

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1346

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1355

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1356

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

333

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

334

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

335

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3335

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3336

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3345

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3346

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

3355

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3356

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

433

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

434

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

435

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4335

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4336

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

4345

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4346

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4355

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4356

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

1337

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1347

Rated current: 63 A
3P+PE
IP 67 oder IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1357

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

13375

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13376

Rated current: 63 A
2P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13475

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13476

Rated current: 63 A
3P+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13575

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13576

Rated current: 63 A
3P+N+PE
IP 67 or IP 66/IP 67
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1331

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

1341

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

1351

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13351

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13361

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13451

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13461

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13551

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

13561

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

3331

Rated current: 63 A
2P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3341

Rated current: 63 A
3P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

3351

Rated current: 63 A
3P+N+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

33351

Rated current: 63 A
2P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

33361

Rated current: 63 A
2P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

33451

Rated current: 63 A
3P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

33461

Rated current: 63 A
3P+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

33551

Rated current: 63 A
3P+N+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

33561

Rated current: 63 A
3P+N+PE
IP 44
straight design
see typelist

PCE / ELCEE / SIROX / METECEE

4331

Rated current: 63 A
2P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4341

Rated current: 63 A
3P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

4351

Rated current: 63 A
3P+N+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

43351

Rated current: 63 A
2P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

43361

Rated current: 63 A
2P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

43451

Rated current: 63 A
3P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

43461

Rated current: 63 A
3P+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

43551

Rated current: 63 A
3P+N+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

43561

Rated current: 63 A
3P+N+PE
IP 44
sloping design
see typelist

PCE / ELCEE / SIROX / METECEE

13371

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

13471

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

13571

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

133751

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

133761

Rated current: 63 A
2P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

134751

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

134761

Rated current: 63 A
3P+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

135751

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

135761

Rated current: 63 A
3P+N+PE
IP 44
for wall mounting
see typelist

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

1 3 5 7 5 1 - 6 * v m

Lid axis	
blank	made of PC/ABS
m	made of brass (nickel-plated)
Contacts	
blank	uncoated contacts
v	nickel plated contacts
Colour	
blank	standard type
xs	Midnight series
*	reserved for additional colours
Clock position earthing contact	
1	1 h
2	2 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h
8	8 h (not available in 4- and 5-poles)
9	9 h
10	10 h
11	11 h
12	12 h
Customer type	
-	Trademark PCE
Degree of protection	
blank	IP67 or IP66/IP67
1	IP44
Pilot contact	
blank	without pilot contact
5	with pilot contact
6	with PCS system
Housing (only for series 13....)	
blank	housing H170 x W118
7	housing H262 x W 162
Poles	
3	3-poles
4	4-poles
5	5-poles
Rated current	
3	63A
Ground type	
1	Wall mounted socket
3	Flanged socket straight
4	Flanged socket sloping

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
333	63	1	Other ratings	Other ratings	500*), 690
433		2	>50	>300 - 500	500*), 690
133		3	>50 – 250	DC	500*), 690
1337		4	100 – 130	50 and 60	500*), 690
3335		6	200 – 250	50 and 60	500*), 690
4335		7	480 – 500	50 and 60	500*), 690
1335		8**)	>250	DC	500*), 690
13375		9	380 – 415	50 and 60	500*), 690
3336*)		10	>50	>100 - 300	500*), 690
4336*)		12	Supply from an isolating transformer	50 and 60	500*), 690
1336*)					
13376*)					
334		63	1	Other ratings	Other ratings
434	2		>50	>300 - 500	500*), 690
134	3		380	50	500*), 690
1347			440	60	
3345	4		100 – 130	50 and 60	500*), 690
4345	5		600 – 690	50 and 60	690
1345	6		380 – 415	50 and 60	500*), 690
13475	7		480 - 500	50 and 60	500*), 690
3346*)	9		200 – 250	50 and 60	500*), 690
4346*)	10		>50	>100 - 300	500*), 690
1346*)	11		440 – 460	60	500*), 690
13476*)	12		Supply from an isolating transformer	50 and 60	500*), 690
335	63		1	Other ratings	Other ratings
435		2	>50	>300 - 500	500*), 690
135		3	220/380	50	500*), 690
1357			250/440	60	
3355		4	57/100 – 75/130	50 and 60	500*), 690
4355		5	347/600 – 400/690	50 and 60	690
1355		6	200/346 – 240/415	50 and 60	500*), 690
13575		7	277/480 – 288/500	50 and 60	500*), 690
3356*)		9	120/208 – 144/250	50 and 60	500*), 690
4356*)		10	>50	>100 - 300	500*), 690
1356*)		11	250/440 – 265/460	60	500*), 690
13576*)		12	Supply from an isolating transformer	50 and 60	500*), 690

*) Types 1336, 13376, 3336, 4336, 1346, 13476, 3346, 4346, 1356, 13576, 3356, 4356 with insulation voltage 500 V and with add. marking: "Only for use with electrical interlock"

***) Earthing contact position 8h > 250V DC only for types 1335, 13375, 3335, 4335, 1336, 13376, 3336, 4336 with add. marking: "Only for use with electrical interlock"

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V	
3331	63	1	Other ratings	Other ratings	500*), 690	
4331		2	>50	>300 - 500	500*), 690	
1331		3	>50 – 250	DC	500*), 690	
13371		4	100 – 130	50 and 60	500*), 690	
33351		6	200 – 250	50 and 60	500*), 690	
43351		7	480 – 500	50 and 60	500*), 690	
13351		8**)	>250	DC	500*), 690	
133751		9	380 – 415	50 and 60	500*), 690	
33361*)		10	>50	>100 - 300	500*), 690	
43361*)		12	Supply from an isolating transformer	50 and 60	500*), 690	
13361*)						
133761*)						
3341		63	1	Other ratings	Other ratings	500*), 690
4341			2	>50	>300 - 500	500*), 690
1341	3		380	50	500*), 690	
13471			440	60		
33451	4		100 – 130	50 and 60	500*), 690	
43451	5		600 – 690	50 and 60	690	
13451	6		380 – 415	50 and 60	500*), 690	
134751	7		480 - 500	50 and 60	500*), 690	
33461*)	9		200 – 250	50 and 60	500*), 690	
43461*)	10		>50	>100 - 300	500*), 690	
13461*)	11		440 – 460	60	500*), 690	
134761*)	12		Supply from an isolating transformer	50 and 60	500*), 690	
3351	63		1	Other ratings	Other ratings	500*), 690
4351			2	>50	>300 - 500	500*), 690
1351		3	220/380	50	500*), 690	
13571			250/440	60		
33551		4	57/100 – 75/130	50 and 60	500*), 690	
43551		5	347/600 – 400/690	50 and 60	690	
13551		6	200/346 – 240/415	50 and 60	500*), 690	
135751		7	277/480 – 288/500	50 and 60	500*), 690	
33561*)		9	120/208 – 144/250	50 and 60	500*), 690	
43561*)		10	>50	>100 - 300	500*), 690	
13561*)		11	250/440 – 265/460	60	500*), 690	
135761*)		12	Supply from an isolating transformer	50 and 60	500*), 690	

*) Types 13361, 133761, 33361, 43361, 13461, 134761, 33461, 43461, 13561, 135761, 33561, 43561 with insulation voltage 500 V and with add. marking: "Only for use with electrical interlock"

***) Earthing contact position 8h > 250V DC only for types 13351, 133751, 33351, 43351, 13361, 133761, 33361, 43361 with add. marking: "Only for use with electrical interlock"

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.