

Certificate



Aktiengesellschaft

No. z2921a-12-E

Customer:

Schrack Technik GmbH
Seybelgasse 13
A-1235 Wien

Test sample(s):

- Connector:
**SCHRACK TOOLLESS LINE Module RJ45
unshielded Cat.6 De-Embedded**
Part No.: HSEMRJ6UWS

Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)

Results:

Up to a bandwidth of **250 MHz** the sample meet the **Category 6** limits of the specified standards and regulations.

Connector, Category 6

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified Products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2921a-12-E**, dated **April 16th, 2012** and shall only be applicable in conjunction with the test report.

Bexbach, April 16th, 2012

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de