

ENERTECH Hungaria Kft
Muszerész köz 4
HU-2440 Szazhalombatta
Hungary

Villmergen, 22 October, 2019

Certificate of conformity

Dear Ladies and gentlemen

We herewith confirm that our Low Voltage Products are tested in accordance and are in conformity with EN 50393 (Test methods and requirements for accessories for use on distribution cables of rated voltage 0,6/1,0(1,2)kV).

We herewith confirm that our Medium Voltage Products up to 20.8/36(42)kV are tested in accordance and are in conformity with CENELEC Standards HD 629.1 and HD 629.2 (Test requirements on accessories for use on power cables of rated voltage from 3,6/6(7,2) kV up to 20,8/36(42)kV).

We herewith confirm that our lugs and connectors are tested in accordance and are in conformity with IEC 61238-1(Compression and mechanical connectors for power cables for rated voltages up to 36kV (Um=42kV)).

CELLPACK-description:

SEH2	Heat shrinkable spreader cap
SEH3	Heat shrinkable spreader cap
SEH4	Heat shrinkable spreader cap
SEH5	Heat shrinkable spreader cap

CELLPACK
Electrical Products

BBG GROUP company

CELLPACK
Electrical Products

CH-5612 Villmergen
Switzerland

Giovanni Prebianca
Area Sales Manager



Michael Steffen
Export Project Manager

